

SCHOOL INSPECTION FORM

ESTABLISHMENT I.D. NO.						EMPLOYEE I.D.			MO.		DAY		YR.		CODE		INSP. TIME			TRAVEL TIME			ARRIVAL TIME			
4	9	E	0	6	8	1	5	1	0	5	1	8	1	8	0	8	0	1	.4	0	0	.3	1	2	1	2

Facility Name: LOG COLLEGE MIDDLE SCHOOL Responsible Party: CENTENNIAL SCHOOL DISTRICT

Address 730 NORRISTOWN RD WARMINSTER PA Zip 18974

Based on an inspection this day, the items marked below identify the violations in operations or facilities which must be corrected by the next routine inspection or shorter period of time as may be specified in writing by the Department.

ITEM	WT.	VIOL.	ITEM	WT.	VIOL.
PLAN REVIEW			LOCKER ROOMS, BATH, AND TOILET FACILITIES		
1 New construction, remodeling	3		11 Clean, sufficient, good repair	4	
2 Facility approved by Department	3		FLOORS, WALLS, CEILINGS		
VECTOR CONTROL			12 Constructed, clean, good repair	3	
* 3 Insect, rodent, animal	5		LIGHTING, GENERAL, EMERGENCY		
SEWAGE AND WASTE WATER DISPOSAL			13 Sufficient, good repair	3	
* 4 Sewage and Waste Water Disposal	5		HEATING AND VENTILATION		
WATER SUPPLY			14 Direct, properly vented, good repair	3	
* 5 Safe, source, hot and cold under pressure	5		15 Inspection of electrical installations	2	
6 Water Samples taken on a routine basis	2		GARBAGE AND REFUSE		
SAFETY			16 Proper collection	3	
7 Reduction of Hazards; building, grounds, equipment	3		17 Storage; insect-rodent proof, covered, adequate, clean, good repair	3	
8 Plumbing; installed and maintained	4		18 Disposal; Proper handling, adequate	3	
CROSS-CONNECTIONS			19 Cleaning areas; washed down, kept clean	3	
* 9 Between potable and non-potable	5		BACK SIPHONAGE		
* 10 Backflow prevention	5		20 Capacity of building; Rooms/individuals; over crowding	3	

PURPOSE

- REINSPECTION..... 1
- INITIAL..... 2
- NEW FACILITY..... 3
- COMPLIANCE..... 4
- COMPLAINT..... 5
- EPIDEMIOLOGY..... 6
- OTHER..... 7

WATER SUPPLY  
NO. SAMPLES COLLECTED  
BACTERIOLOGICAL:  
CHEMICAL:

DISINFECTION REQUIRED:  
Yes  No   
RESIDUAL PPM

PUBLIC BATHING PLACE PROVIDED  
Yes  No   
If yes, see inspection form

FOOD SERVICE PROVIDED  
Yes  No   
If yes, see inspection form

ADDITIONAL REMARKS ON

Yes <input type="checkbox"/>	Facility Approved	No <input type="checkbox"/>	NA <input type="checkbox"/>
------------------------------	-------------------	-----------------------------	-----------------------------

FOLLOW-UP Yes <input type="checkbox"/> No <input type="checkbox"/>	RATING SCORE <b>70</b>
---	---------------------------

MAXIMUM RATING \_\_\_\_\_ SCORE \_\_\_\_\_  
SCHOOL \_\_\_\_\_ 70

\*Critical Items Requiring Immediate Attention.

Received by: name *Robert Whartenby*  
title Robert Whartenby

Inspected by: name *[Signature]*  
title \_\_\_\_\_

FACILITY

**INSPECTION ITEM  
NARRATIVE DESCRIPTION**


FACILITY NAME LOG COLLEGE MIDDLE SCHOOL	INSPECTION DATE 05/18/2018	FACILITY I.D. / TAX MAP NO. 49E068 / 49-009-033-0000-0000-0000
--	-------------------------------	---

ITEM NO	REMARKS	TO BE CORRECTED BY
---------	---------	--------------------

**General Remarks**

A complaint was received regarding renovation activities being conducted at the school. Numerous documents, plans, presentations, etc. are available on the school's website and were reviewed prior to inspection. No deviations from these were noted during the inspection, or while interviewing building officials, facilities staff and/or contractors. Asbestos abatement is being conducted in the building to include mechanical/boiler rooms and corridors. The work being conducted in mechanical/boiler rooms is taking place during the week through the use of containment (poly sheeting) and negative pressure. Environmental samples are reportedly collected and analyzed prior to removing containmant systems. Work in corridors is conducted similarly, with the exception of weekends only (starting 5.19.18). A third-party monitor is required to be onsite during the course of the project to assure full adherance to applicable regulations. Cleanup from corridor ceiling removal includes containment (to remove dirt/dust) and cleaning from the contractor and school district custodial staff. Corridors are closed to all, other than contractors approved to be in the containment area(s). Air scrubbers are being utilized in areas of higher concern.

--	--	--

Received by:

Inspected by:

FACILITY